

BUSTAMANTE REFRIGERATION L.L.C

780 N. INDUSTRIAL PARK RD.
NOGALES, AZ. 85621
PHONE (520) 281-2766 FAX (520) 377-0022
bref@qwestoffice.net

August 26, 2016

N.U.S.D. #1
310 W. Plum St.
Nogales, Az. 85621

To Whom It May Concern:

This letter is concerning and existing Carrier gas pack air conditioner model # 48DD016D located at the Nogales High School band room. This unit is 34 years old and has damaged in-door and out-door coils. Specifically, the in-door coils have deteriorated so much that when the coil is repaired by being welded, a new leak occurs due to the poor condition of the copper. The unit is pretty much not repairable any more and extremely inefficient due to the constant loss of charge and the constant repair work. We recommend that N.U.S.D installs a new system that is both efficient and reliable.

If there are any questions concerning the system please don't hesitate to contact us at (520) 31-9165 or (520) 281-2766

Thank you,

Bustamante Refrigeration L.L.C

BUSTAMANTE REFRIGERATION L.L.C

780 N. INDUSTRIAL PARK RD.

NOGALES, AZ. 85621

PHONE (520) 281-2766 FAX (520) 377-0022

brf@gwestoffice.net

Proposal submitted to: N.U.S.D #1

Date: 08/26/16

310 W. Plum St
Nogales, Az. 85621

Job: Band room

The following proposal is submitted to N.U.S.D #1 for the installation of 1, commercial grade gas electric package unit. The following is included in installation:

- 1) Remove existing system and deliver to N.U.S.D maintenance yard
- 2) Manual fresh air intake
- 3) Hail guards
- 4) Re-route high volt electrical to new system
- 5) Re-route low volt electrical to new system
- 6) Re-route natural gas piping to new system
- 7) Re-route condensate drain piping to new system
- 8) 1, Curb adapter to match existing ducting to new system
- 9) Seal system water tight
- 10) Test new system for proper operation
- 11) We will need to replace fuse and circuit breaker size if customer opts for 20 Ton system.

Note: Equipment pricing being quoted is for work to be performed during regular work week hours. System carries a 1 year manufacturers compressor and parts warranty. Install carries a 1 year warranty. American Standard equipment requires a 15 day build plus a 5 day delivery period. York systems are in stock and can be delivered in two days.

We propose to do the above job for the amount of \$

OPTION #1: American Standard 15 Ton system \$ 19,700.00

OPTION #2: American Standard 20 Ton system \$ 24,000.00

OPTION #3: York 15 Ton system \$ 23,770.00

OPTION #4: York 20 Ton system \$ 27,470.00

Thank you,

Accepted,